

November 21, 2016

Dear Pine Grove Middle School Community:

I'd like to take this opportunity to inform you that we now have received all lead test data from samples of water that were taken recently from Pine Grove Middle School. Of the 117 samples tested (see next pages), 12 sources at Pine Grove currently exceed the permissible limit (15 ppb), as defined by the new NY State law. Test results for those 12 sources are as follows:

G200 sink #1	43 ppb*
G200 sink #2	42 ppb*
G200 sink #3	49 ppb*
G200 sink #4	60 ppb*
G201 sink #1	23 ppb*
G201 sink #2	22 ppb*
G201 sink #3	18 ppb*
G201 sink #4	32 ppb*
G202 sink #1	20 ppb*
G202 sink #2	17 ppb*
G202 sink #3	18 ppb*
G202 sink #4	22 ppb*

All 12 sources are faucets found in the school's art rooms. The water to these faucets has been shut off and we are awaiting delivery of replacement faucets that will be sampled and tested as soon as they are installed.

For a full list of Pine Grove results, please see the next pages.

Thank you for your patience throughout this process.

Sincerely,



John Young
Director of Facilities

Pine Grove Middle School

Sample Date - 10/5/2016

* indicates that source reading exceeds 9/6/16 permissible level (15 ppb)

Room	Lead	Actions Taken
Kitchen sink left	3.1 ppb	
Kitchen sink right	5 ppb	
Kitchen wash sink	<1 ppb	
DF near C109 short	<1 ppb	
DF near C109 tall	<1 ppb	
Rm. 105	<1 ppb	
Rm. 104	13 ppb	
100 sink #1	<1 ppb	
100 sink #2	<1 ppb	
100 sink #3	<1 ppb	
100 sink #4	<1 ppb	
100 hand sink	9.4 ppb	
101 sink	6.7 ppb	
Rm. 102	3.4 ppb	
103 bathroom	<1 ppb	
Men BR near 103 right	<1 ppb	
Men BR near 103 left	<1 ppb	
109 staff room	3.5 ppb	
DF near B103 short	<1 ppb	
DF near B103 tall	<1 ppb	
Boys' BR near B102 #1	<1 ppb	
Boys' BR near B102 #2	<1 ppb	
Boys' BR near B102 #3	1 ppb	
Women BR left	<1 ppb	
Women BR right	<1 ppb	
Girls' BR near B102 #1	<1 ppb	
Girls' BR near B102 #2	<1 ppb	
Girls' BR near B102 #3	8.9 ppb	
B102	5.9 ppb	
A113	5.8 ppb	
A100	3.2 ppb	
DF near Rm. 100 short	<1 ppb	
DF near Rm. 100 tall	<1 ppb	
Girls' BR sink tall	1.2 ppb	
Girls' BR sink short	1.2 ppb	
Boys' BR sink tall	3.4 ppb	
Boys' BR sink short	2.1 ppb	

DF foyer tall	<1 ppb
DF foyer short	<1 ppb
Main Office sink	<1 ppb
Girls' BR near E102 tall	<1 ppb
Girls' BR near E102 sht	<1 ppb
Boys' BR near E102 sht	<1 ppb
Boys' BR near E102 tall	<1 ppb
DF near gym tall	<1 ppb
DF near gym short	<1 ppb
DF near gym w/bottle	<1 ppb
D103 DF	3.0 ppb
D103 sink	1.6 ppb
D102 sink	1.2 ppb
BR across from D108	<1 ppb
Girls' locker room BR	<1 ppb
Girls' LR BR sink short	<1 ppb
Girl's LR BR sink tall	<1 ppb
DF near E117 tall	<1 ppb
DF near E117 short	<1 ppb
DF bottle filler nr E117	<1 ppb
E116 Coach BR	<1 ppb
E116 Boys' LR sink #1	<1 ppb
E116 Boys' LR sink #2	<1 ppb
E116 Boys' LR sink #3	<1 ppb
E120 Coach BR	1.1 ppb
E109A sink	<1 ppb
E107 sink #1	<1 ppb
E107 sink #2	5.1 ppb
E107 Nurse bathroom	<1 ppb
E108 bathroom	<1 ppb
Boys' BR sink #1 212B	<1 ppb
Boys' BR sink #2 212B	<1 ppb
Girls' BR sink #1 212B	<1 ppb
Girl's BR sink #2 212B	<1 ppb
Library Office	3.8 ppb
2nd fl DF tall Area 7	1.3 ppb
2nd fl DF short Area 7	<1 ppb
F200 sink #1	<1 ppb
F200 sink #2	<1 ppb
F202 sink #1	2.3 ppb
F202 sink #2	2.2 ppb

F211 sink #1	<1 ppb	
F211 sink #2	<1 ppb	
F213 sink #1	1.1 ppb	
F213 sink #2	1.1 ppb	
G200 sink #1	43 ppb*	shut down outlet, waiting for lead-free replacement faucet
G200 sink #2	42 ppb*	shut down outlet, waiting for lead-free replacement faucet
G200 sink #3	49 ppb*	shut down outlet, waiting for lead-free replacement faucet
G200 snk #4	60 ppb*	shut down outlet, waiting for lead-free replacement faucet
G201 sink #1	23 ppb*	shut down outlet, waiting for lead-free replacement faucet
G201 sink #2	22 ppb*	shut down outlet, waiting for lead-free replacement faucet
G201 sink #3	18 ppb*	shut down outlet, waiting for lead-free replacement faucet
G201 sink #4	32 ppb*	shut down outlet, waiting for lead-free replacement faucet
G202 sink #1	20 ppb*	shut down outlet, waiting for lead-free replacement faucet
G202 sink #2	17 ppb*	shut down outlet, waiting for lead-free replacement faucet
G202 sink #3	18 ppb*	shut down outlet, waiting for lead-free replacement faucet
G202 sink #4	22 ppb*	shut down outlet, waiting for lead-free replacement faucet
G203 Girls' BR sink #1	1.1 ppb	
G203 Girls' BR sink #2	<1 ppb	
G203 Girls' BR sink #3	1.3 ppb	
G203 Boys' BR sink #1	1.5 ppb	
G203 Boys' BR sink #2	<1 ppb	
G203 Boys' BR sink #3	1.6 ppb	
G203 DF tall	<1 ppb	
G203 DF short	<1 ppb	
G203 Women BR snk 1	1.3 ppb	
G203 Women BR snk 2	<1 ppb	
G204 Men BR sink #1	<1 ppb	
G204 Men BR sink #2	<1 ppb	
G204 sink #1	<1 ppb	
G201 DF tall	1.3 ppb	
G201 DF short	<1 ppb	
H200 sink #1	1.8 ppb	
H200 sink #2	<1 ppb	
H202 sink #1	<1 ppb	
H202 sink #2	<1 ppb	
H211 sink #1	3.2 ppb	
H211 sink #2	<1 ppb	
H213 sink #1	1 ppb	
H213 sink #2	<1 ppb	