



District Office
407 Fremont Road
East Syracuse, NY 13057
Fax: 315-434-3025
www.esmschools.org

John Young
Director of Facilities

Phone: 315-434-3001
Email: johnyoung@esmschools.org

October 14, 2016

Dear Fremont Elementary School Community:

I'd like to take this opportunity to inform you that we now have received all lead test data from samples of water that were taken from Fremont Elementary School prior to the Governor's September 6 signing of the law mandating such. Of 30 samples tested (see below), there currently are no readings from the building that exceed the permissible exposure limit (15 ppb) as defined by the new state law.

As of September 6, the law prescribes that additional outlets in the building be sampled and tested. Those samples were drawn in September and we expect to receive the results shortly. Once received, the results will be made available on the district's website.

Thank you for your patience throughout this process.

Sincerely,

A handwritten signature in blue ink, appearing to read "John Young", is written over a faint, circular blue stamp or watermark.

John Young
Director of Facilities

Fremont Elementary

* indicates that source reading exceeds 9/6/16 permissible level (15 ppb)

Room	Lead	Actions Taken	Actions Planned
Kitchen sink	12 ppb		
Café DF L	2.2 ppb		
Café DF R	2.6 ppb		
Main Hall DF tall	<1 ppb		
Main Hall Dfshort	<1 ppb		
Library sink	1.3 ppb		
Main Office sink	1.2 ppb		
106 sink	<1 ppb		
110 DF	<1 ppb		
112 DF	<1 ppb		
111 DF	<1 ppb		
11 DF	12 ppb		
12 DF	6.9 ppb		
13 DF	7.4 ppb		
14 DF	4.8 ppb		
15 DF	12 ppb		
16 DF	11 ppb		
17 DF	7 ppb		
18 DF	9.7 ppb		
19 DF	13 ppb		
20 DF	3 ppb		
21 DF	8.6 ppb		
22 DF	3.9 ppb		
23 DF	3.7 ppb		
24 DF	1.8 ppb		
25 DF	4.3 ppb		
26 DF	2.3 ppb		
27 DF	3.4 ppb		
28 sink	<1 ppb		
29 sink	9.9 ppb		