

**Minoa Elementary 4-27-20**

Room	lead(ppb)	
kitchen	3.6	
cafe DF right	<1.0	
cafe DF left	<1.0	
hallway DF tall	<1.0	
hallway DF short	<1.0	
A-1 sink	<1.0	
2 DF	7.8	
2 sink	5.9	
Nurse's exam sink	8	
Nurse's bathroom	<1.0	
Nurse's hand sink	<1.0	
3 DF	3.8	
3 sink	6	
4 right sink	2.6	
4 left sink	2.6	
5 DF	4.6	
5 sink	2	
6 DF	10	
6 sink	8.4	
7 DF	3.6	
7 sink	5	
8 DF	8.2	
8 sink	3.4	
9 DF	16*	shut down for removal
9 sink	9.2	
10 sink	1.7	
11 DF	10	
11 sink	15*	shut down, valve tagged out of service
21 DF	6.2	
21 sink	6.1	
22 DF	3.9	
22 sink	5.8	
23 DF	7.3	
23 sink	8.1	
24 DF	<1.0	

24 sink	<1.0	
25 DF	<1.0	
25 sink	<1.0	
26 DF	5.4	
26 sink	3.4	
27 DF	6.7	
27 sink	6.1	
28 DF	1.8	
28 sink	1.6	
13 DF	2.6	
13 sink	2.5	
14 sink	1.4	
15 DF	3.8	
15 sink	4.4	
16 DF	<1.0	
16 sink	1.7	
17 DF	8	
17 sink	2.6	
18 DF	12	
18 sink	3	
19 DF	4.4	
19 sink	4.2	
20 sink	<1.0	