



District Office
407 Fremont Road
East Syracuse, NY 13057
Fax: 315-434-3025
www.esmschools.org

John Young
Director of Facilities

Phone: 315-434-3001
Email: johnyoung@esmschools.org

October 14, 2016

Dear Park Hill School Community:

I'd like to take this opportunity to inform you that we now have received all lead test data from samples of water that were taken from Park Hill School prior to the Governor's September 6 signing of the law mandating such. Of 15 samples tested (see below), there currently are no readings from the building that exceed the permissible exposure limit (15 ppb) as defined by the new state law.

As of September 6, the law prescribes that additional outlets in the building be sampled and tested. Those samples were drawn in September and we expect to receive the results shortly. Once received, the results will be made available on the district's website.

Thank you for your patience throughout this process.

Sincerely,

A handwritten signature in blue ink, appearing to read "John Young", is written over a faint, light blue circular stamp or watermark.

John Young
Director of Facilities

Park Hill Pre-K

* indicates that source reading exceeds 9/6/16 permissible level (15 ppb)

Room	Lead	Actions Taken	Actions Planned
Kitchen sink	15 ppb	installed in-line filter	
Cafeteria DF left	1.3 ppb		
Cafeteria DF right	9.5 ppb		
305 sink	8.4 ppb		
Nurse's front sink	4.2 ppb		
Nurse's back sink	9.3 ppb		
Basement DF	<1 ppb		
6 sink	8.1 ppb		
Basement sink	5.2 ppb		
104 sink	<1 ppb		
1st Floor Hallway DF	2.1 ppb		
103A sink	1.7 ppb		
208 sink	3.4 ppb		
2nd Floor DF	5.1 ppb		
2nd fl. womens' R	3.9 ppb		