

Woodland Elementary

Room	Lead
Main Office sink	<1 ppb
Nurse's Hallway DF	<1 ppb
Kitchen sink #1	3.9 ppb
Kitchen sink #2	<1 ppb
Nurse's Office	<1 ppb
Library breakroom	4.2 ppb
Cust. Hallway DF	3.1 ppb
108 Custodial sink	2.6 ppb
DF near Rm. 133	<1 ppb
137 sink #1	2.5 ppb
137 sink #2	<1 ppb
Hallway DF tall	<1 ppb
Hallway DF short	<1 ppb
Teachers' breakrm.	4.1 ppb
118 DF	7.9 ppb
119 DF	5.1 ppb
Hallway DF near 118	4.4 ppb
120 DF	6.2 ppb
121 DF	3.5 ppb
122 DF	3.9 ppb
123 DF	3.6 ppb
124 DF	3.7 ppb
125 DF	4.7 ppb
127 DF	6.9 ppb
128 DF	6.6 ppb

Room	Lead
Boys' bath near cust.	<1 ppb
Girls' bath near cust	<1 ppb
Nurse's bath	<1 ppb
Rm. 128 bath	2.2 ppb
Rm. 128 sink	6.5 ppb
Rm. 127 bath	5.6 ppb
Rm. 127 sink	1.1 ppb
Rm. 126 sink	6.3 ppb
Rm. 114 fountain	4.1 ppb
Rm. 114 sink	2.3 ppb
Rm. 115 sink	1.2 ppb
Rm. 118 sink	3.4 ppb
Rm. 118 bath	<1 ppb
Rm. 119 sink	1.5 ppb
Rm. 119 bath	1.4 ppb
Rm. 121 sink	4.7 ppb
Rm. 121 bath	1.6 ppb
Rm. 120 sink	3.7 ppb

Rm. 120 bath	1ppb
Rm. 122 sink	13 ppb
Rm. 122 bath	2 ppb
Rm. 123 sink	4.5 ppb
Rm. 123 bath	1.8 ppb
Rm. 124 sink	7.7 ppb
Rm. 124 bath	2.1 ppb
Rm. 125 sink	4 ppb
Rm. 125 bath	1.2 ppb
Rm. 144 sink	1 ppb
Rm. 145 sink	<1 ppb
Rm. 142 sink	2.3 ppb
Rm. 143 sink	1.4 ppb
Rm. 154 boys' bath 1	<1 ppb
Rm. 154 boys' bath 2	<1 ppb
Rm. 154 boys' bath 3	<1 ppb
Rm. 154 boys' bath 4	<1 ppb
Rm. 139 sink	2.2 ppb
Rm. 140 sink	3.5 ppb
Rm. 136 bathroom	1.1 ppb
Rm. 135 sink	3.6 ppb
Rm. 132 sink	1.2 ppb
Rm. 149 girls' bath 1	<1 ppb
Rm. 149 girls' bath 2	<1 ppb
Rm. 149 girls' sink#3	<1 ppb
Rm. 149 girls' sink#4	<1 ppb
Rm. 133 sink	3.7 ppb
Rm. 130 sink	<1 ppb
Rmf. 131 sink	5.6 ppb
Rm. 146 sink #1	7.2 ppb
Rm. 146 sink #2	3.1 ppb

* indicates that source reading exceeds 9/6/16 permissible level (15 ppb)

Results listed in bold received on 10/13/2016